

ID :93 Sunoli Bridge _ _ _ _ _

on Chainage 124.830 of Jyolikot Almora Karanprayag national highway

In District Almora Under NH Ranikhet Division

Bridge Inventory Report

Division: NH Ranikhet

Data not-yet finalized

General

Name of Division : 83

Revenue Block Name : 66

Chainage (at Mid Point) : 124.830

Road/ Segment Name : 12

Bridge Type : Motor Bridge High Level

Structure No : 125/4

Feature Intersected : Sunoli Gadhera/Nala

Name of Bridge : Sunoli Bridge

Nearest Town : Kafda

Latitude (Northing) : 29.70920000

Longitude (Easting) : 79.43740000

Construction Year : 1962

Inventory Year : 2020

Geometric

Overall length (in meter) : 15.30

Total No of Span : 1

Maximum Span (in meter) : 15.30

Span Arrangement : 1X15.30

No of Lane : 1.000

Overall Width (m) : 5.250

Carriageway Width (m) : 4.250

RS Footpath Width (m) : 0.000

LS Footpath Width (m) : 0.000

Approach Width i/c Shoulders (m) : 7.500

Gradient (%age) : 0

Skew Angle (degree) : 0.00

Radius of Curve in Plan (if Any) : 0.00

Design Data

HFL Highest Flood Level :

OFL Ordinary Flood Level :

LWL Low Water Level :

Design Velocity (m/Sec) :

Design Discharge (Cumecs) :

Soffit Level at Centre :

Road Level at Centre :

Design Scour Level at Pier :

Design Scour Level at Abutments :

Exposure Condition : Moderate

Seismic Importance factor : 0.0

Design Loading : Class B
Load Rating : NA
Super-Structure
Superstructure Type : T-beam and slab
Superstructure Material : Masonry
Wearing Coat Type : Bituminous Concrete
Expansion Joint Type : Not Provided
Railing/Crash Barrier type : Cast-in-situ concrete
Bearing type : Not Provided
Sub-Structure
Founding Strata : Rocky
Abutment Foundation Type : Open
Pier Foundation Type : NA
No of Piers : 0
Abutment Type : Stone Masonry
Pier Type : NA
Protection Work
Bank Protection Left Side of Up-stream : no protection work provided
Bank Protection Right Side of Up-stream : no protection work provided
Bank Protection Left Side of Down-stream : no protection work provided
Bank Protection Right Side of Down-stream : no protection work provided
Floor Protection on Up-stream : no protection work provided
Floor Protection on Down-stream : no protection work provided
Treatment for Corrosion Protection (if any) : no special treatment provided
final
Name of JE/AAE : Er. Deep Chaudhary

